

PRODUCT CERTIFICATE OF REGISTRATION



Global Certification Pty Ltd

Number 567

Product Performance Testing

AS 1546.3:2017

Advanced Secondary 10EP Level

Issued to

Civilmart Icon Septech Victoria

11 Industrial Drive Pakenham Victoria 3810

Certification Date: - 23 May 2020 Expiry Date: - 22 May 2025

Product Certified:

Model	Disinfection	Average Results over the Test Period	Servicing Frequency	Discharge	Manufactured and assembled
TurboJet single advanced secondary treatment System	Yes	TSS 9.2mg/l BOD ₅ <2mg/l Total Nitrogen 51.1mg/l Phosphorus 11.6mg/l Turbidity 8.8NTU E coli <1CFU/100ml	3 Monthly Service 3.5 yearly sedimentation pump out or as required	Pumped via disinfection/pump chamber with chlorine dispenser	Manufactured and Assembled: 32 Cumners Road Torrington Qld 4350
The system took 7 weeks to meet the advanced secondary standard. It is serviced 3 monthly.					

NACE CODES: 3700

This Certificate of Conformance to the Product Certificate Scheme for "Domestic Wastewater Treatment Units (Septic Tanks) and Rainwater Tanks" remains the property of Global Certification Pty. Ltd. and is granted subject to the terms and conditions of the Contract Application, in respect of the Product certified on this page and the attached schedule to the Certification of Conformance, bearing the same number as this certificate.

Date of Issue: 23rd May 2020

Bruce Smith Director



www.jas-anz.com.au/register

Signed for and on behalf of Global Certification Pty Ltd
PO Box 195, Morayfield QLD 4506